



Burlington, WA	Corporate Laboratory (a)	1620 S Walnut St	Burlington, WA 98233	800.755.9295 • 360.757.1400
Bellingham, WA	Microbiology (b)	805 Orchard Dr Ste 4	Bellingham, WA 98225	360.715.1212
Portland, OR	Microbiology/Chemistry (c)	9150 SW Pioneer Ct Site W	Wilsonville, OR 97070	503.682.7802
Corvallis, OR	Microbiology (d)	540 SW Third Street	Corvallis, OR 97333	541.753.4946



BOTTLED WATER STANDARD OF QUALITY REPORT

Client Name: Sweetwater Company, Inc.
812 C St.
Culver, OR 97734

Reference Number: **16-21195**

Authorized by:

Aleesha K Skora
Lab Manager, Bend

Project: 2016 Annual Source

Field ID:

Sample Description: Source

Sampled By: Russell Mireles

Sample Date: 08/29/2016

Lab Number: 52339

Report Date: 10/11/2016

Approved By: aks,anp,bj,co,fm,hy,ljh,mcs

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
7440-70-2	CALCIUM	5.8		0.5	mg/L	200.7	a	
7439-95-4	MAGNESIUM	5.9		0.5	mg/L	200.7	a	
7440-23-5	SODIUM	10.8		0.50	mg/L	200.7	a	
7440-09-7	POTASSIUM	2.3		1.0	mg/L	200.7	a	
E-10184	ELECTRICAL CONDUCTIVITY	127	700	10	uS/cm	SM2510 B	a	
24959-67-9	BROMIDE	0.011		0.005	mg/L	300.1	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDR or IBWA.

MRL - Method Reporting Limit .

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact us at the above phone number.

BOTTLED WATER STANDARD OF QUALITY REPORT

Inorganic Chemicals (IOCs)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
57-12-5	CYANIDE, FREE	ND	0.2	0.010	mg/L	OIA-1677-DW	a	
7440-36-0	ANTIMONY	ND	0.006	0.001	mg/L	200.8	a	
7440-38-2	ARSENIC	0.002	0.010	0.001	mg/L	200.8	a	
7440-39-3	BARIUM	0.002	1.0	0.001	mg/L	200.8	a	
7440-41-7	BERYLLIUM	ND	0.004	0.001	mg/L	200.8	a	
7440-43-9	CADMIUM	ND	0.005	0.001	mg/L	200.8	a	
7440-47-3	CHROMIUM	0.001	0.05	0.001	mg/L	200.8	a	
16984-48-8	FLUORIDE	0.11	2	0.1	mg/L	300.0	a	
7439-92-1	LEAD	ND	0.005	0.001	mg/L	200.8	a	
7439-97-6	MERCURY	ND	0.001	0.0002	mg/L	245.1	a	
7440-02-0	NICKEL	ND	0.1	0.001	mg/L	200.8	a	
7782-49-2	SELENIUM	ND	0.010	0.005	mg/L	200.8	a	
7440-28-0	THALLIUM	ND	0.002	0.001	mg/L	200.8	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit .

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.

BOTTLED WATER STANDARD OF QUALITY REPORT

EPA Regulated

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
14797-65-0	NITRITE-N	ND		0.005	mg/L	SM4500-NO3 F	c	
E-10128	TOTAL NITRATE/NITRITE	0.18		0.01	mg/L	SM4500-NO3 F	c	
7429-90-5	ALUMINUM	ND	0.2	0.010	mg/L	200.7	a	
16887-00-6	CHLORIDE	1.7	250	0.1	mg/L	300.0	a	
7440-50-8	COPPER	ND	1.0	0.005	mg/L	200.8	a	
7439-89-6	IRON	ND	0.3	0.050	mg/L	200.7	a	
7439-96-5	MANGANESE	ND	0.05	0.001	mg/L	200.8	a	
7440-22-4	SILVER	ND	0.025	0.001	mg/L	200.8	a	
14808-79-8	SULFATE	1.2	250	10	mg/L	300.0	a	
E-10173	TOTAL DISSOLVED SOLIDS (TDS)	96	500	10	mg/L	SM2540 C	a	
7440-66-6	ZINC	ND	5.00	0.005	mg/L	200.8	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit .

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.

BOTTLED WATER STANDARD OF QUALITY REPORT

EPA Regulated

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
14797-55-8	NITRATE-N	0.17	10	0.005	mg/L	SM4500-NO3 F	c	
75-35-4	1,1 - DICHLOROETHYLENE	ND	2	0.4	ug/L	524.2	a	
71-55-6	1,1,1 - TRICHLOROETHANE	ND	30	0.4	ug/L	524.2	a	
79-00-5	1,1,2 - TRICHLOROETHANE	ND	5	0.4	ug/L	524.2	a	
107-06-2	1,2 - DICHLOROETHANE	ND	2	0.4	ug/L	524.2	a	
78-87-5	1,2 - DICHLOROPROPANE	ND	5	0.4	ug/L	524.2	a	
120-82-1	1,2,4 - TRICHLOROBENZENE	ND	9	0.4	ug/L	524.2	a	
71-43-2	BENZENE	ND	1	0.4	ug/L	524.2	a	
56-23-5	CARBON TETRACHLORIDE	ND	2	0.4	ug/L	524.2	a	
156-59-2	CIS - 1,2 - DICHLOROETHYLENE	ND	70	0.4	ug/L	524.2	a	
156-60-5	TRANS - 1,2 - DICHLOROETHYLENE	ND	100	0.4	ug/L	524.2	a	
100-41-4	ETHYLBENZENE	ND	700	0.4	ug/L	524.2	a	
75-09-2	DICHLOROMETHANE	ND	3	0.4	ug/L	524.2	a	
108-90-7	MONOCHLOROBENZENE	ND	50	0.4	ug/L	524.2	a	
95-50-1	O - DICHLOROBENZENE	ND	600	0.4	ug/L	524.2	a	
106-46-7	P - DICHLOROBENZENE	ND	75	0.4	ug/L	524.2	a	
100-42-5	STYRENE	ND	100	0.4	ug/L	524.2	a	
127-18-4	TETRACHLOROETHYLENE	ND	1	0.4	ug/L	524.2	a	
108-88-3	TOLUENE	ND	1000	0.4	ug/L	524.2	a	
79-01-6	TRICHLOROETHYLENE	ND	1	0.4	ug/L	524.2	a	
75-01-4	VINYL CHLORIDE	ND	2	0.4	ug/L	524.2	a	
1330-20-7	XYLENES (TOTAL)	ND	1000	0.4	ug/L	524.2	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit .

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.

BOTTLED WATER STANDARD OF QUALITY REPORT

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
18540-29-9	* HEXAVALENT CHROMIUM	1.097		0.030	ug/L	218.6	a	
94-75-7	2,4 - D	ND	70	0.1	ug/L	515.4	a	
93-72-1	2,4,5 - TP (SILVEX)	ND	10	0.2	ug/L	515.4	a	
16655-82-6	3-HYDROXYCARBOFURAN	ND			ug/L	531.2	a	
15972-60-8	ALACHLOR	ND	2	0.2	ug/L	525.2	a	
116-06-3	ALDICARB	ND		1.0	ug/L	531.2	a	
1646-88-4	ALDICARB SULFONE	ND		1.6	ug/L	531.2	a	
1646-87-3	ALDICARB SULFOXIDE	ND		1.0	ug/L	531.2	a	
309-00-2	ALDRIN	ND		0.1	ug/L	525.2	a	
1912-24-9	ATRAZINE	ND	3	0.1	ug/L	525.2	a	
50-32-8	BENZO(A)PYRENE	ND	0.2	0.02	ug/L	525.2	a	
23184-66-9	BUTACHLOR	ND		0.1	ug/L	525.2	a	
63-25-2	CARBARYL	ND			ug/L	531.2	a	
1563-66-2	CARBOFURAN	ND	40	0.9	ug/L	531.2	a	
57-74-9	CHLORDANE	ND	0.5	0.2	ug/L	508.1	a	
75-99-0	DALAPON	ND	200	1	ug/L	515.4	a	
103-23-1	DI(ETHYLHEXYL)-ADIPATE	ND	400	0.6	ug/L	525.2	a	
117-81-7	DI(ETHYLHEXYL)-PHTHALATE	ND	6	0.6	ug/L	525.2	a	
96-12-8	1,2-DIBROMO-3-CHLOROPROPANE (D	ND	0.2	0.02	ug/L	504.1	a	
1918-00-9	DICAMBA	ND		0.2	ug/L	515.4	a	
60-57-1	DIELDRIN	ND		0.1	ug/L	525.2	a	
88-85-7	DINOSEB	ND	7	0.2	ug/L	515.4	a	
41903-57-5	DIOXIN (2,3,7,8-TETRACHLORODIBEN;	ND	30	5	pg/L	1613		Analyzed by PACE_MN
85-00-7	DIQUAT	ND	20	0.4	ug/L	549.2	a	
145-73-3	ENDOTHALL	ND	100	9	ug/L	548.1	a	
72-20-8	ENDRIN	ND	0.2	0.01	ug/L	525.2	a	
106-93-4	1,2 - DIBROMOETHANE (EDB)	ND	0.05	0.01	ug/L	504.1	a	
1071-83-6	GLYPHOSATE	ND	700	6	ug/L	547	a	
76-44-8	HEPTACHLOR	ND	0.4	0.04	ug/L	525.2	a	
1024-57-3	HEPTACHLOR EPOXIDE "B"	ND	0.2	0.02	ug/L	525.2	a	
118-74-1	HEXACHLOROBENZENE	ND	1	0.1	ug/L	525.2	a	
77-47-4	HEXACHLOROCYCLO-PENTADIENE	ND	50	0.1	ug/L	525.2	a	
58-89-9	LINDANE (BHC - GAMMA)	ND	0.2	0.02	ug/L	525.2	a	
16752-77-5	METHOMYL	ND			ug/L	531.2	a	
72-43-5	METHOXYCHLOR	ND	40	0.1	ug/L	525.2	a	
51218-45-2	METOLACHLOR	ND		0.1	ug/L	525.2	a	
21087-64-9	METRIBUZIN	ND		0.1	ug/L	525.2	a	
23135-22-0	OXAMYL (VYDATE)	ND	200	2	ug/L	531.2	a	
87-86-5	PENTACHLOROPHENOL	ND	1	0.04	ug/L	515.4	a	
1918-02-1	PICLORAM	ND	500	0.1	ug/L	515.4	a	
1336-36-3	POLYCHLORINATED BIPHENYLS (PCB	ND	0.5	0.1	ug/L	508.1	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit .

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.



Reference Number: **16-21195**

Lab Number: **52339**

Report Date: **10/11/2016**

BOTTLED WATER STANDARD OF QUALITY REPORT

Page 6 of 13

1918-16-7	PROPACHLOR	ND		0.1	ug/L	525.2	a	
122-34-9	SIMAZINE	ND	4	0.07	ug/L	525.2	a	
8001-35-2	TOXAPHENE	ND	3	1	ug/L	508.1	a	
E-10253	TOTAL PHENOLIC COMPOUNDS	ND	1	1	ug/L	420.4		Analyzed by NSF

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit .

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.

BOTTLED WATER STANDARD OF QUALITY REPORT

Water Properties

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
1332-21-4	* ASBESTOS	ND	7	0.20	MFL>10urr	100.2		Analyzed by EMSL
NA	* TASTE	ND				SM2160 B	a	
E-10139	HYDROGEN ION (pH)	7.32			pH Units	SM4500-H+ B	c	
NA	* MBAS (Surfactants)	ND			mg/L	SM5540 C		Analyzed By NSF
E-11712	COLOR	ND	15	5	COLOR UI	SM2120 B	c	pH: 7.32
E-11734	ODOR	ND	3	0	TON	SM2150	a	Temperature: 39.4
E-10617	TURBIDITY	0.42	1	0.02	NTU	180.1	c	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit .

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.

BOTTLED WATER STANDARD OF QUALITY REPORT

Disinfectants/DBP

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
15541-45-4	BROMATE	ND	0.010	0.001	mg/L	300.1	a	
7758-19-2	CHLORITE	ND	1.00	0.010	mg/L	300.1	a	
NA	HAA(5)	ND	60	2	ug/L	552.3	a	DUP: ND
79-43-6	DICHLOROACETIC ACID	ND		1	ug/L	552.3	a	
76-03-9	TRICHLOROACETIC ACID	ND		1	ug/L	552.3	a	
631-64-1	DIBROMOACETIC ACID	ND		1	ug/L	552.3	a	
79-11-8	MONOCHLOROACETIC ACID	ND		2	ug/L	552.3	a	
79-08-3	MONOBROMOACETIC ACID	ND		1	ug/L	552.3	a	
E-14471	TOTAL TRIHALOMETHANE	ND	10	0.4	ug/L	524.2	a	
75-27-4	BROMODICHLOROMETHANE	ND		0.4	ug/L	524.2	a	
124-48-1	CHLORODIBROMOMETHANE	ND		0.4	ug/L	524.2	a	
67-66-3	CHLOROFORM	ND		0.4	ug/L	524.2	a	
75-25-2	BROMOFORM	ND		0.4	ug/L	524.2	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.
 MRL - Method Reporting Limit .

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.

BOTTLED WATER STANDARD OF QUALITY REPORT

Radiological Contaminants

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
12587-46-1	GROSS ALPHA	ND	15	3	pCi/L	900.0		Analyzed by Pace
12587-47-2	GROSS BETA	ND	50	4	pCi/L	900.0		Analyzed by Pace
13982-63-3	RADIUM 226	ND		1	pCi/L	903.1		Analyzed by Pace
15262-20-1	RADIUM 228	ND	5	1	pCi/L	904.0		Analyzed by Pace
7440-61-1	URANIUM	ND	0.030	0.001	mg/L	200.8	a	
14859-67-7	RADON	100		50	pCi/L	SM7500-Rn B		Analyzed by EEA IN

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.
 MRL - Method Reporting Limit .

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.

BOTTLED WATER STANDARD OF QUALITY REPORT

Additional Volatile Organic Chemicals (New York)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
542-75-6	1,3-DICHLOROPROPYLENE, TOTAL	ND		0.5	ug/L	524.2	a	
75-34-3	1,1 - DICHLOROETHANE	ND		0.5	ug/L	524.2	a	
563-58-6	1,1 - DICHLOROPROPENE	ND		0.5	ug/L	524.2	a	
630-20-6	1,1,1,2 - TETRACHLOROETHANE	ND		0.5	ug/L	524.2	a	
79-34-5	1,1,2,2 - TETRACHLOROETHANE	ND		0.5	ug/L	524.2	a	
87-61-6	1,2,3 - TRICHLOROBENZENE	ND		0.5	ug/L	524.2	a	
96-18-4	1,2,3 - TRICHLOROPROPANE	ND		0.5	ug/L	524.2	a	
95-63-6	1,2,4 - TRIMETHYLBENZENE	ND		0.5	ug/L	524.2	a	
142-28-9	1,3 - DICHLOROPROPANE	ND		0.5	ug/L	524.2	a	
108-67-8	1,3,5 - TRIMETHYLBENZENE	ND		0.5	ug/L	524.2	a	
594-20-7	2,2 - DICHLOROPROPANE	ND		0.5	ug/L	524.2	a	
108-86-1	BROMOBENZENE	ND		0.5	ug/L	524.2	a	
74-97-5	BROMOCHLOROMETHANE	ND		0.5	ug/L	524.2	a	
74-83-9	BROMOMETHANE	ND		0.5	ug/L	524.2	a	
75-00-3	CHLOROETHANE	ND		0.5	ug/L	524.2	a	
74-87-3	CHLOROMETHANE	ND		0.5	ug/L	524.2	a	
10061-01-5	CIS - 1,3 - DICHLOROPROPENE	ND		0.5	ug/L	524.2	a	
74-95-3	DIBROMOMETHANE	ND		0.5	ug/L	524.2	a	
75-71-8	DICHLORODIFLUOROMETHANE	ND		0.5	ug/L	524.2	a	
87-68-3	HEXACHLOROBUTADIENE	ND		0.5	ug/L	524.2	a	
98-82-8	ISOPROPYLBENZENE	ND		0.5	ug/L	524.2	a	
541-73-1	M - DICHLOROBENZENE	ND		0.5	ug/L	524.2	a	
1330-20-7	M/P - XYLENE	ND		0.5	ug/L	524.2	a	
1634-04-4	METHYL TERT-BUTYL ETHER	ND		0.5	ug/L	524.2	a	
104-51-8	N - BUTYLBENZENE	ND		0.5	ug/L	524.2	a	
103-65-1	N - PROPYLBENZENE	ND		0.5	ug/L	524.2	a	
91-20-3	NAPHTHALENE	ND	14	0.5	ug/L	524.2	a	
95-49-8	O - CHLOROTOLUENE	ND		0.5	ug/L	524.2	a	
106-43-4	P - CHLOROTOLUENE	ND		0.5	ug/L	524.2	a	
95-47-6	O - XYLENE	ND		0.5	ug/L	524.2	a	
99-87-6	P - ISOPROPYLTOLUENE	ND		0.5	ug/L	524.2	a	
135-98-8	SEC - BUTYLBENZENE	ND		0.5	ug/L	524.2	a	
98-06-6	TERT - BUTYLBENZENE	ND		0.5	ug/L	524.2	a	
10061-02-6	TRANS- 1,3 - DICHLOROPROPENE	ND		0.5	ug/L	524.2	a	
75-69-4	TRICHLOROFLUOROMETHANE	ND		0.5	ug/L	524.2	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit .

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.

BOTTLED WATER STANDARD OF QUALITY REPORT

Additional Inorganic Chemicals (New York)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
E-11778	HARDNESS	38.8		10	mg CaCO ₃	200.7	a	
E-14506	ALKALINITY	62		1	mg CaCO ₃	SM2320 B	a	
NA	* CORROSIVITY	-1.85			SI	SM203	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit .

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.

BOTTLED WATER STANDARD OF QUALITY REPORT

Inorganic Chemicals (Massachusetts)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
1497-73-0	PERCHLORATE	ND	0.002	0.001	mg/L	331.0		Analyzed by Eurofins Eaton - Monro

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.
 MRL - Method Reporting Limit .

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.



Reference Number: **16-21195**

Lab Number: **52339**

Report Date: **10/11/2016**

BOTTLED WATER STANDARD OF QUALITY REPORT

Page 13 of 13

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
	* TOTAL COLIFORM For Taste	A	0	P/A	per 100mL	SM9223 B	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit .

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.